



CERTIFICATE OF PRODUCT VERIFICATION

This is to certify that

Extra Co Fibre Glass & Prefab Houses. L.L.C.

P. O. Box 6174,
Emirates Industrial Area, Sajja,
Sharjah,
United Arab Emirates

Meets the requirements of the BMTV **Product Verification**
Fire Door Manufacture scheme to STD 01 for **the products**
on the attached schedule

Compliance officer

BM TRADA VENTURES LLC

Certificate number: 002

Issue number: 2025-02

Certificate last issue date: 20 September 2025

Certificate expiry date: 10 November 2027

Date of initial certification: 11 November 2022

This organization was previously certified to
Q-Mark since 18 September 2006



BMTV, Unit 904 Business Avenue Building, Deira, Dubai, United Arab Emirates

This certificate remains the property of BMTV. This certificate and all copies or reproductions of the certificate shall be returned to BMTV or destroyed if requested. Further clarification regarding the scope of this certificate and verification of the certificate is available through BMTV at the above address or at www.bmtr-ventures.com
This certificate remains unauthenticated without the SEAL of AUTHENTICATION on the signature

Registration Schedule

Head Office Address

P. O. Box 6174,
Industrial Area no. 02, Yanbou St.
Sharjah,
United Arab Emirates

Factory 1 Address

(Timber Doors)
Extra Co Fibre Glass & prefab Houses L.L.C
P. O. Box 6174,
Emirates Industrial Area, Sajja, Plot no. 6357-6359,
Sharjah, United Arab Emirates

Factory 2 Address

(Steel Doors)
Extra Co Industries L.L.C
P. O. Box 21391
Al Ghail Industrial Area/Zone P,
Ras Al Khaimah, United Arab Emirates

Scope

Primary Field of Application (FoA) Reports (owned by this certified company)

Primary FoA reports owned by this PV certified company are listed on the PV-Mark certificate along with the latest revision status. They are either used in isolation or can be used in conjunction with an appropriate associated document that is listed below, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

FoA Report	Rev	Owned by Certified Company named on this scope	Doorset Description	Rating	Test Type
Chilt/A06138	D	Extra Co Fibre Glass & Prefab Houses. L.L.C.	Extra Co Horizontal Access Hatches (Steel) – 120	120min	BS 476 Pt22

Primary Field of Application Reports (owned by and cascaded by a System Supplier)

Primary FoA reports owned by a System Supplier are listed on the PV-Mark certificate. The revision status of each FoA can be verified on the BMTV website under each System Supplier's certification entry. They are either used in isolation or can be used in conjunction with an appropriate associated document that is listed below, providing that the FoA report allows it and that both documents are compatible with each other.

Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

FoA Report	System Supplier owner of Assessment Report	Doorset Description	Rating	Test Type
Chilt/A1204 Part 1	Halspan Ltd.	Extra Co – HO – 30 (Glazed/Unglazed)	30min	BS 476 Pt22
Chilt/A01205 Part 1	Halspan Ltd.	Extra Co – HO – 60 (Glazed/Unglazed)	60min	BS 476 Pt22
Chilt/A05151	Halspan Ltd.	Extra Co – HE – 90 (Glazed/Unglazed)	90min	BS 476 Pt22
BMT/CNA/F15082	Halspan Ltd.	Extra Co – H – 120 (Glazed/Unglazed)	120min	BS 476 Pt22
Chilt/A06218	Warm Springs Composite Panels Products	Extra Co – WS – 120 (Glazed/Unglazed)	120min	BS 476 Pt22

Test Reports

Test reports are listed on the PV-Mark certificate. They cannot be used in conjunction with any primary FoA reports, test reports or associated documents. They must be followed precisely without any deviation whatsoever.

No specification or parameter changes are allowed at all from that stated within the test report such as size, shape, design, glazing, leaf/frame specification, hardware etc.

Test Report	Owner of Test Report	Doorset Description	Rating	Test Type
Material Lab/ 160314250	Extra Co Fibre Glass & Prefab Houses. L.L.C.	Extra Co – Latched Single Acting Single Wooden Door – 90	90min	BS 476 Pt22
Material Lab/ 151231232	Extra Co Fibre Glass & Prefab Houses. L.L.C.	Extra Co – Latched Single Acting Single Wooden Door – 60	60min	BS 476 Pt22
Chilt/IF06023 AR1	Extra Co Fibre Glass & Prefab Houses. L.L.C.	Extra Co – Steel Manhole access – 120	120min	BS 476 Pt22