CERTIFICATE OF PRODUCT VERIFICATION

This is to certify that

Vulcan Industries LLC

Corner 2,
Jurf Industrial Zone1,
P. O. Box 15007,
Ajman
United Arab Emirates

Meets the requirements of the BMTV **Product Verification** Fire Door Manufacture scheme to STD 01 for **the products on the attached schedule**

Compliance officer

BM TRADA VENTURES LLC

CB-PRD-009

BMTV, Unit 904 Business Avenue Building, Deira, Dubai, United Arab Emirates

Certificate number: 010

Issue No: 2026 - 01

Certificate last issue date: 25 January 2025

Certificate expiry date: 29 January 2028

Date of initial certification: 30 January 2023

This certificate remains the property of BMTV. This certificate and all copies or reproductions of the certificate shall be returned to BMTV or destroyed if requested. Further clarification regarding the scope of this certificate and verification of the certificate is available through BMTV at the above address or at www.bmtr-ventures.com
This certificate remains unauthenticated without the SEAL of AUTHENICATION on the signature

Registration Schedule

Establishment

Vulcan Industries LLC

Address

Corner 2,
Jurf Industrial Zone 1,
P. O. Box 15007,
Ajman,
United Arab Emirates

Scope

Pimary Field of Application (FoA) Reports (owned by this certified company)

Primary FoA reports owned by this PV certified company are listed on the PV-Mark certificate along with the latest revision status. They are either used in isolation or can be used in conjunction with an appropriate associated document that is listed below, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

FoA Report	Rev	Owned by Certified Company named on this scope	Doorset Description	Rating	Test Type
		NA			

Primary Field of Application Reports (owned by and cascaded by a System Supplier)

Primary FoA reports owned by a System Supplier are listed on the PV-Mark certificate. The revision status of each FoA can be verified on the BMTV website under each System Supplier's certification entry. They are either used in isolation or can be used in conjunction with an appropriate associat ed document that is listed below, providing that the FoA report allows it and that both documents are compatible with each other.
Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

FoA Report	System Supplier owner of Assessment Report	Doorset Description	Rating	Test Type
Chilt/A01205 P1 & P2	Halspan Ltd.	Vulcan Industries – HO – 60 (Glazed and Unglazed)	60min	BS 476 Pt22
FEA/F96103 P1 & P2	Halspan Ltd.	Vulcan Industries – HP – 60 (Glazed and Unglazed)	60min	BS 476 Pt22
Chilt/A05151	Halspan Ltd.	Vulcan Industries – HE – 90 (Glazed and Unglazed)	90min	BS 476 Pt22
PAR/10346/02	Gulf Trade Link FZCO	Vulcan Industries -FB - 60 (Glazed/Unglazed)	60min	BS 476 Pt22
PAR/11018/01	Gulf Trade Link FZCO	Vulcan Industries -FB - 90 (Glazed/Unglazed)	90min	BS 476 Pt22
PAR/13335/01	Gulf Trade Link FZCO	Vulcan Industries -FB - 120 (Glazed/Unglazed)	120min	BS 476 Pt22

Test Reports

Test reports are listed on the PV-Mark certificate. They cannot be used in conjunction with any primary FoA reports, test reports or associated documents. They must be followed precisely without any deviation whatsoever.

No specification or parameter changes are allowed at all from that stated within the test report such as size, shape, design, glazing, leaf/frame specification, hardware etc.

Test Report	Owner of Test Report	Doorset Description	Rating	Test Type
161226408, Lab ref: 525290 C1-2 SN1/2 A	Vulcan Industries LLC	Vulcan Industries- LSASLWD-90 Glazed	90min	BS 476 Pt22
170129439, Lab ref: STQ-170131/125 C1-2 SN1/2	Vulcan Industries LLC	Vulcan Industries- LSASLWD-120 Glazed	120min	BS 476 Pt22
TBWC - RD093 (Rev.02)	Vulcan Industries LLC	Vulcan Industries – FB60 (Doorset A) Unglazed opening away from the fire	60min	BS 476 Pt22
		Vulcan Industries – FB60 (Doorset B) Unglazed opening away from the fire	60min	