



# CERTIFICATE OF PRODUCT VERIFICATION

This is to certify that

## Interwood Mobel (Pvt.) Ltd.

56-Sultan Mehmood Road  
Shalimar Town  
Lahore  
Pakistan

Meets the requirements of the BMTV **Product Verification** Fire Door  
Manufacture scheme to STD 01 for **the products on the attached schedule**

Compliance officer

BM TRADA VENTURES LLC

Certificate number: 022

Issue No: 01 - 2026

Certificate last issue date: 22 June 2026

Certificate expiry date: 14 August 2028

Date of initial certification: 15 August 2023



BMTV, Unit 904 Business Avenue Building, Deira, Dubai, United Arab Emirates

This certificate remains the property of BMTV. This certificate and all copies or reproductions of the certificate shall be returned to BMTV or destroyed if requested. Further clarification regarding the scope of this certificate and verification of the certificate is available through BMTV at the above address or at [www.bmt-ventures.com](http://www.bmt-ventures.com)

## Registration Schedule

**Establishment**  
Interwood Mobil (Pvt.) Ltd.

**Address**  
56-Sultan Mehmood Road  
Shalimar Town  
Lahore  
Pakistan

### Scope

Primary Field of Application Reports (owned by and cascaded by a System Supplier)

Primary FoA reports owned by a System Supplier are listed on the PV-Mark certificate. The revision status of each FoA can be verified on the BMTV website under each System Supplier's certification entry. They are either used in isolation or can be used in conjunction with an appropriate associated document that is listed below, providing that the FoA report allows it and that both documents are compatible with each other.

Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

FoA Report	System Supplier owner of Assessment Report	Doorset Description	Rating	Test Type
Chilt/A01204 Part 1	Halspan Ltd.	Interwood Mobil – HO – 30 Timber Based Door Frame Glazed/unglazed 30min	30min	BS 476 Pt22
Chilt/A01205 Part 1	Halspan Ltd.	Interwood Mobil – HO – 60 Timber Based Door Frames Glazed/unglazed 60min	60min	BS 476 Pt22
Chilt/A01205 Part 2	Halspan Ltd.	Interwood Mobil – HO – 60 Steel Based Door Frames Glazed/unglazed 60min	60min	BS 476 Pt22
FEA/F96103 Part 1	Halspan Ltd.	Interwood Mobil – HP – 60 (Glazed/ Unglazed)	60min	BS 476 Pt22
FEA/F96103 Part 2	Halspan Ltd.	Interwood Mobil – HP – 60 (Glazed/ Unglazed)	60min	BS 476 Pt22
Chilt/A05151	Halspan Ltd.	Interwood Mobil – HE – 90 (Glazed/ Unglazed)	90min	BS 476 Pt22
WF389581	Halspan Ltd.	Interwood Mobil – HPP – 90 (Glazed/ Unglazed)	90min	BS 476 Pt22
BMT/CNA/F15082	Halspan Ltd.	Interwood Mobil – H – 120 (Glazed/ Unglazed)	120min	BS 476 Pt22

Test Reports

Test reports are listed on the PV-Mark certificate. They cannot be used in conjunction with any primary FoA reports, test reports or associated documents. They must be followed precisely without any deviation whatsoever.

*No specification or parameter changes are allowed at all from that stated within the test report such as size, shape, design, glazing, leaf/frame specification, hardware etc..*

Test Report	Owner of Test Report	Doorset Description	Rating	Test Type
QH056- A	Interwood Mobil (Pvt.) Ltd.	Interwood Mobil – LSASD – Steel- 120 (Unglazed)	120min	BS 476 Pt22