



CERTIFICATE OF PRODUCT VERIFICATION

This is to certify that

Depa Industrial (DIG) LLC

P.O. Box 6537

DIP 1 Plot 598-665

Dubai, United Arab Emirates

Meets the requirements of the BMTV **Product Verification**
Fire Door Manufacture scheme to STD 01 for **the products**
on the attached schedule

Compliance officer

BM TRADA VENTURES LLC



BMTV, Unit 904 Business Avenue Building, Deira, Dubai, United Arab Emirates

This certificate remains the property of BMTV. This certificate and all copies or reproductions of the certificate shall be returned to BMTV or destroyed if requested. Further clarification regarding the scope of this certificate and verification of the certificate is available through BMTV at the above address or at www.bmt-ventures.com

This certificate remains unauthenticated without the SEAL of AUTHENTICATION on the signature

Certificate number: 019

Issue no: 2025 - 01

Certificate last issue date: 27 March 2025

Certificate expiry date: 11 June 2028

Date of initial certification: 12 June 2023

Registration Schedule

Establishment
Depa Industrial (DIG) LLC

Address
P.O. Box 6537,
DIP 1 Plot 598-665,
Dubai, United Arab Emirates

Scope

Primary Field of Application (FoA) Reports (owned by this certified company)

Primary FoA reports owned by this PV certified company are listed on the PV-Mark certificate along with the latest revision status. They are either used in isolation or can be used in conjunction with an appropriate associated document that is listed below, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

FoA Report	Rev	Owned by Certified Company named on this scope	Doorset Description	Rating	Test Type
		NA			

Primary Field of Application Reports (owned by and cascaded by a System Supplier)

Primary FoA reports owned by a System Supplier are listed on the PV-Mark certificate. The revision status of each FoA can be verified on the BMTV website under each System Supplier's certification entry. They are either used in isolation or can be used in conjunction with an appropriate associated document that is listed below, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

FoA Report	System supplier owner of FoA Report	Doorset Description	Rating	Test Type
FEA/F96103 Part 1	Halspan Ltd.	DEPA – HP – 60 (Glazed/Unglazed) Timber-based door frames	60min	BS 476 Pt22
FEA/F96103 Part 2	Halspan Ltd.	DEPA – HP – 60 (Glazed/Unglazed) Steel Frame Doorsets	60min	BS 476 Pt22
FEA/F97097	Halspan Ltd.	DEPA – HPP – 30 (Glazed/Unglazed)	30min	BS 476 Pt22
Chilt/A05151	Halspan Ltd.	DEPA – HE – 90 (Glazed/Unglazed)	90min	BS 476 Pt22
BMT/CNA/F15082	Halspan Ltd.	DEPA – H – 120 (Glazed/Unglazed)	120min	BS 476 Pt22
Chilt/A06218	Warm Springs Composite Products	DEPA – WS – 120 (Glazed/Unglazed)	120min	BS 476 Pt22
WF409922	Moralt Laminasse	DEPA – MLF - 54mm (Glazed/Unglazed)	30min	BS 476 Pt22
WF409922	Moralt Laminasse	DEPA – MLF - 54mm (Glazed/Unglazed)	60min	BS 476 Pt22
PAR/10346/01	Gulf Trade Link FZCO	Fireban Board 44mm thick FD30 BS 476 Part 22	30min	BS 476 Pt22

PAR/10346/02	Gulf Trade Link FZCO	Fireban Board 54mm thick FD60 BS 476 Part 22	60min	BS 476 Pt22
PAR/11018/01	Gulf Trade Link FZCO	Fireban Board 64mm thick FD90 BS 476 Part 22	90min	BS 476 Pt22
PAR/13335/01	Gulf Trade Link FZCO	Fireban Board 64mm thick FD120 BS 476 Part 22	120min	BS 476 Pt22

Test Reports

Test reports are listed on the PV-Mark certificate. They cannot be used in conjunction with any primary FoA reports, test reports or associated documents. They must be followed precisely without any deviation whatsoever.

No specification or parameter changes are allowed at all from that stated within the test report such as size, shape, design, glazing, leaf/frame specification, hardware etc.

Test Report	Owner of Test Report	Doorset Description	Rating	Test Type
180304578 (TPWR-1803/1168 A SN 1/1)	DEPA Industrial (DIG) LLC	DEPA – LSADD – 60 (Unglazed)	60min	BS 476 Pt22
380258*AR1 (Rev A)	DEPA Industrial (DIG) LLC	DEPA – LSADD – 120 (Unglazed)	120min	BS 476 Pt22
BMT/FEP/F16109 (Rev. B)	DEPA Industrial (DIG) LLC	DEPA – LSADD – 90 (Glazed)	90min	BS 476 Pt22
BMT/FEP/F16038 (Rev. B)	DEPA Industrial (DIG) LLC	DEPA – LSADD – 60 (Glazed)	60min	BS 476 Pt22
161225407 (525020 D C 1-2 SN 1/1)	DEPA Industrial (DIG) LLC	DEPA – LSASD – 60 (Specimen-1 Unglazed)	60min	BS 476 Pt22
161225407 (525020 D C 1-2 SN 1/1)	DEPA Industrial (DIG) LLC	DEPA - LSASD – 60 with vision panel (Specimen-2)	60 min	BS 476 Pt22
160901333 (511962 C C 1-2 SN 1/2)	DEPA Industrial (DIG) LLC	DEPA – LSASD – 90 – with vision panel (Specimen-2)	90 min	BS 476 Pt22
160905337 (511960 C C 1-2 SN 2/2)	DEPA Industrial (DIG) LLC	DEPA – LSASD – 120 – with vision panel (Specimen-2)	120min	BS 476 Pt22
TG135- 1&2 Rev03	DEPA Industrial (DIG) LLC	DEPA – LSASD – Doorset (A) 60 (Unglazed)	60min	BS 476 Pt22
TG135- 1&2 Rev03	DEPA Industrial (DIG) LLC	DEPA – LSASD – Doorset (B) 90 (Unglazed)	90min	BS 476 Pt22
SJ186-3 Rev01	DEPA Industrial (DIG) LLC	DEPA – LSASD – Doorset (A) 90 (Unglazed)	90min	BS 476 Pt22
SJ186-3 Rev01	DEPA Industrial (DIG) LLC	DEPA – LSASD – Doorset (B) 60 (Unglazed)	60min	BS 476 Pt22
TG085-1	DEPA Industrial (DIG) LLC	DEPA – LSASD with vision panel	60min	BS 476 Pt22