



CERTIFICATE OF PRODUCT VERIFICATION

This is to certify that

Al Karnak Furniture & Décor LLC

Al Sajaa Industrial Area, Plot 6/1861
P.O. Box 29740
Sharjah
United Arab Emirates

Meets the requirements of the BMTV **Product Verification**
Fire Door Manufacture scheme to STD 01 for **the products on the**
attached schedule

Compliance Officer
BMTV LLC

Certificate number: 027

Issue No: 2025 - 01

Certificate last issue date: 30 October 2025

Certificate expiry date: 20 December 2028

Date of initial certification: 21 December 2023



BMTV, Unit 904 Business Avenue Building, Deira, Dubai, United Arab Emirates

This certificate remains the property of BMTV. This certificate and all copies or reproductions of the certificate shall be returned to BMTV or destroyed if requested. Further clarification regarding the scope of this certificate and verification of the certificate is available through BMTV at the above address or at www.bmtr-ventures.com
This certificate remains unauthenticated without the SEAL of AUTHENTICATION on the signature

Registration Schedule

Establishment

Al Karnak Furniture & Décor LLC

Address

Al Sajaa Industrial Area, Plot 6/1861
P.O. Box 29740
Sharjah
United Arab Emirates

Scope

Primary Field of Application (FoA) Reports (owned by this certified company)

Primary FoA reports owned by this PV certified company are listed on the PV-Mark certificate along with the latest revision status. They are either used in isolation or can be used in conjunction with an appropriate associated document that is listed below, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

FoA Report	Rev	Owned by Certified Company named on this scope	Doorset Description	Rating	Test Type

Primary Field of Application Reports (owned by and cascaded by a System Supplier)

Primary FoA reports owned by a System Supplier are listed on the PV-Mark certificate. The revision status of each FoA can be verified on the BMTV website under each System Supplier's certification entry. They are either used in isolation or can be used in conjunction with an appropriate associated document that is listed below, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

FoA Report	System Supplier owner of Assessment Report	Doorset Description	Rating	Test Type
Chilt/A01204 Part 1	Halspan Ltd.	Al Karnak – HO – 30 Glazed/Unglazed	30min	BS 476 Pt22
Chilt/A01204 Part 2	Halspan Ltd.	Al Karnak – HO – 30 Glazed/Unglazed	30min	BS 476 Pt22
Chilt/A01205 Part 1	Halspan Ltd.	Al Karnak – HO – 60 Glazed/Unglazed	60min	BS 476 Pt22
Chilt/A01205 Part 2	Halspan Ltd.	Al Karnak – HO – 60 Glazed/Unglazed	60min	BS 476 Pt22
FEA/F97174 Part 1	Halspan Ltd.	Al Karnak – HP – 30 Glazed/Unglazed	30min	BS 476 Pt22
FEA/F97174 Part 2	Halspan Ltd.	Al Karnak – HP – 30 Glazed/Unglazed	30min	BS 476 Pt22
FEA/F97174 Part 3	Halspan Ltd.	Al Karnak – HP – 30 Glazed/Unglazed	30min	BS 476 Pt22
FEA/F96103 Part 1	Halspan Ltd.	Al Karnak – HP – 60 Glazed/Unglazed	60min	BS 476 Pt22
FEA/F96103 Part 2	Halspan Ltd.	Al Karnak – HP – 60 Glazed/Unglazed	60min	BS 476 Pt22
FEA/F96103 Part 3	Halspan Ltd.	Al Karnak – HP – 60 Glazed/Unglazed	60min	BS 476 Pt22
Chilt/A05151	Halspan Ltd.	Al Karnak – HE – 90 Glazed/Unglazed	90min	BS 476 Pt22

Test Reports

Test reports are listed on the PV-Mark certificate. They cannot be used in conjunction with any primary FoA reports, test reports or associated documents. They must be followed precisely without any deviation whatsoever.

No specification or parameter changes are allowed at all from that stated within the test report such as size, shape, design, glazing, leaf/frame specification, hardware etc..

Test Report	Owner of Test Report	Doorset Description	Rating	Test Type
BMT/FEP/F16050	Al Karnak Furniture Decor L.L.C	Al Karnak - Halspan-LSASD-30 (Doorset B) Unglazed	30min	BS 476 Pt22
BMT/FEP/F16050	Al Karnak Furniture Decor L.L.C	Al Karnak - Halspan-LSASD-60 (Doorset A) Unglazed	60min	BS 476 Pt22
BMT/FEP/F16051	Al Karnak Furniture Decor L.L.C	Al Karnak - Halspan-LSASD-90 Unglazed	90min	BS 476 Pt22