



CERTIFICATE OF PRODUCT VERIFICATION

This is to certify that

The Joiners Carpentry

Barwa Commercial Avenue,
Sayer Building Block 53, 2nd Floor,
Industrial Area,
Doha, Qatar

Meets the requirements of the BMTV **Product Verification**
Fire Door Manufacture scheme to STD 01 for **the products**
on the attached schedule

Compliance officer

BM TRADA VENTURES LLC

Certificate number: 040

Issue No: 2025 - 01

Certificate last issue date: 11 September 2025

Certificate expiry date: 10 September 2030

Date of initial certification: 11 September 2025



BMTV, Unit 904 Business Avenue Building, Deira, Dubai, United Arab Emirates

This certificate remains the property of BMTV. This certificate and all copies or reproductions of the certificate shall be returned to BMTV or destroyed if requested. Further clarification regarding the scope of this certificate and verification of the certificate is available through BMTV at the above address or at www.bmtr-ventures.com
This certificate remains unauthenticated without the SEAL of AUTHENTICATION on the signature

Registration Schedule

Head Office Address

Barwa Commercial Avenue,
Sayer Building Block 53, 2nd Floor,
Industrial Area,
Doha, Qatar

Factory Address

Building no. 6, Street 536,
Zone 57, Industrial Area,
Doha,
Qatar

Scope

Primary Field of Application (FoA) Reports (owned by this certified company)

Primary FoA reports owned by this PV certified company are listed on the PV-Mark certificate along with the latest revision status. They are either used in isolation or can be used in conjunction with an appropriate associated document that is listed below, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

FoA Report	Rev	Owned by Certified Company named on this scope	Doorset Description	Rating	Test Type
		NA			

Primary Field of Application Reports (owned by and cascaded by a System Supplier)

Primary FoA reports owned by a System Supplier are listed on the PV-Mark certificate. The revision status of each FoA can be verified on the BMTV website under each System Supplier's certification entry. They are either used in isolation or can be used in conjunction with an appropriate associated document that is listed below, providing that the FoA report allows it and that both documents are compatible with each other.

Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

FoA Report	System Supplier owner of Assessment Report	Doorset Description	Rating	Test Type
Chilt/A01204 Part 1	Halspan Ltd.	The Joiners Carpentry- HO- 30 (Timber based frames) glazed/unglazed	30 Min	BS 476 Pt22
Chilt/A01204 Part 2	Halspan Ltd.	The Joiners Carpentry -HO- 30 (Steel or Aluminum based frames) glazed/unglazed	30 Min	BS 476 Pt22
FEA/F97174 Part 1	Halspan Ltd.	The Joiners Carpentry -HOP- 30 (Timber based frames) glazed/unglazed	30 Min	BS 476 Pt22
FEA/F97174 Part 2	Halspan Ltd.	The Joiners Carpentry – HO -30 (Steel or Aluminum based frames) glazed/unglazed	30 Min	BS 476 Pt22
FEA/F97174 Part 3	Halspan Ltd.	The Joiners Carpentry - HP- 30 (Bond up leaves with timber-based door frames) glazed/unglazed	30 Min	BS 476 Pt22
FEA/F97174 Part 5	Halspan Ltd.	The Joiners Carpentry -HP- 30 (Prima Plus 30 Door Blanks in Timber Based & Steel Door Frames) glazed/unglazed	30 Min	BS 476 Pt22
FEA/F96103 Part 1	Halspan Ltd.	The Joiners Carpentry - HP- 60 (Timber Based Door Frames) glazed/unglazed	60 Min	BS 476 Pt22
FEA/F96103 Part 2	Halspan Ltd.	The Joiners Carpentry - HP- 60 (Steel Based Door Frames) glazed/unglazed	60 Min	BS 476 Pt22
FEA/F96103 Part 3	Halspan Ltd.	The Joiners Carpentry -HP- 60 (Bond Up leaves with timber Based Door Frames) glazed/unglazed	60 Min	BS 476 Pt22
FEA/F96103 Part 5	Halspan Ltd.	The Joiners Carpentry - HP- 60 (Prima Plus Door Blanks in Timber Based Door Frames) glazed/unglazed	60 Min	BS 476 Pt22
Chilt/A01205 Part 1	Halspan Ltd.	The Joiners Carpentry - HO- 60 (Timber Based Door Frames) glazed/unglazed	60 Min	BS 476 Pt22

Chilt/A01205 Part 2	Halspan Ltd.	The Joiners Carpentry - HO- 60 (Steel Based Door Frames) glazed/unglazed	60 Min	BS 476 Pt22
Chilt/A05151	Halspan Ltd.	The Joiners Carpentry - Halspan 90 (Doorsets) glazed/unglazed	90 Min	BS 476 Pt22
WF389581	Halspan Ltd.	The Joiners Carpentry -HP Plus - 90 (Timber and Steel based Door Frames) glazed/unglazed	90 Min	BS 476 Pt22
BMT/CNA/F150 82	Halspan Ltd.	The Joiners Carpentry - Halspan 120 glazed/unglazed	120 Min	BS 476 Pt22
WF389580	Halspan Ltd.	The Joiners Carpentry - HP Plus - 120 (Timber and Steel based Door Frames) glazed/unglazed	120 Min	BS 476 Pt22

Test Reports

Test reports are listed on the PV-Mark certificate. They cannot be used in conjunction with any primary FoA reports, test reports or associated documents. They must be followed precisely without any deviation whatsoever.

No specification or parameter changes are allowed at all from that stated within the test report such as size, shape, design, glazing, leaf/frame specification, hardware etc.

Test Report	Owner of Test Report	Doorset Description	Rating	Test Type
	N/A			